

CERTIFICATE

(1) EU-Type Examination

(2) **Component intended for use on/in equipment or protective systems intended for use in potentially explosive atmospheres - Directive 2014/34/EU**

(3) EU-Type Examination Certificate Number: **KEMA 01ATEX2260 U** Issue Number: **6**

(4) Product: **Terminal Blocks ST 10; ST 16 and ST 35
Protective Conductor Terminal blocks ST 10-PE; ST 16-PE
and ST 35-PE**

(5) Manufacturer: **PHOENIX CONTACT GmbH & Co. KG**

(6) Address: **Flachsmarktstrasse 8, 32825 Blomberg, Germany**

(7) This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) DEKRA Certification B.V., Notified Body number 0344 in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential test report number NL/KEM/ExTR06.0034/05.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0 : 2018

EN 60079-7 : 2015 + A1 : 2018

(10) The sign "U" is placed after the certificate number. It indicates that this certificate must not be mistaken for a certificate intended for an equipment or protective system. This partial certification may be used as a basis for certification of an equipment or protective system.

(11) This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

(12) The marking of the product shall include the following:



II 2 GD Ex eb IIC Gb

Date of certification: 27 February 2020

DEKRA Certification B.V.

L.G. van Schie
Certification Manager

Page 1/3



© Integral publication of this certificate and adjoining reports is allowed. This Certificate may only be reproduced in its entirety and without any change.

(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate KEMA 01ATEX2260 U**

Issue No. 6

(15) **Description**

Terminal Blocks (all colours); ST 10, ST 16 and ST 35 and Protective Conductor Terminal Blocks; ST 10-PE, ST 16-PE and ST 35-PE with accessories are intended for the connection of copper conductors in enclosures in type of protection Ex e or Ex t for fixing on mounting rails type NS 35 according to EN 60715-TH 35.

Service temperature range -60 °C to +110 °C.

Electrical data

See Annex 1 to Report NL/KEM/ExTR06.0034/05 for electrical data and nomenclature.

Installation instructions

The instructions provided with the product shall be followed in detail to assure safe operation.

(16) **Report Number**

No. NL/KEM/ExTR06.0034/05.

(17) **Schedule of Limitations**

1. The Terminal Blocks and the Protective Conductor Terminal Blocks shall be mounted in a certified enclosure that meets the requirements of a type of protection as specified in EN 60079-0 clause 1, with a degree of protection at least as required for Ex e. For combustible dust these enclosures must satisfy the requirements according to EN 60079-0 and EN 60079-31.
2. When assembling with other certified series and sizes and using the associated accessories, the required creepage distances and clearances have to be observed.
3. The installation instruction of the manufacturer shall be followed e.g. for the use of cover, jumpers, end brackets. The data regarding current and associated temperature rise shall be used as guideline for the given conductor cross sections. The cross section has influence on the temperature rise which shall be assessed in the end application.
4. If the Terminal Blocks are used in electrical equipment of temperature classes T1 up to T5, the highest temperature of the insulating material shall not exceed the maximum value of the operating temperature range.
5. If the Terminal Blocks are used in electrical equipment of temperature classes T6 the permissible ambient temperature range is $-60\text{ °C} < T_{amb} < +40\text{ °C}$.

(18) **Essential Health and Safety Requirements**

Covered by the standards listed at item (9).

(19) **Test documentation**

As listed in Report No. NL/KEM/ExTR06.0034/05.

(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate KEMA 01ATEX2260 U**

Issue No. **6**

(20) **Certificate history**

Issue 1 - 201667700	Initial certificate.
Issue 2 - 209621200	Assessment to recent edition of standards
Issue 3 - 211801500	Assessment to recent edition of standards
Issue 4 - 215216600	Assessment to recent edition of standards, operating temperature range changed.
Issue 5 - 219710400	Assessment to recent edition of standards, minor constructional changes.
Issue 6 - 224265600	Addition alternative plastic material bridges.